



December 29, 2011

FELKER BROS. CORP.  
RANDY KROGMAN  
22 W. CHESTNUT AVE.  
MARCHFIELD WI 54449

Re: Description: PIPES AND FITTINGS, STAINLESS STEEL  
Manufacturer: FELKER BROS. CORP.  
Product Name: S.S. PIPE AND FTGS  
Model Number(s): WELDED A312 STAINLESS STEEL PIPE, SCH 5S, 10S, 40S, 10, 20, 30, 40 & STD  
Product File No: 20110250

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 84.30 (2) (a) & (b) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This Stainless Steel Pipe may have the following end configurations provided by and in accordance with the manufacture:

**Flanged Ends:** All sizes can be furnished flanged with either flat or angle face rings and back-up flanges (ductile iron, carbon or stainless steel). A full range of metal to metal connectors, through 36" and larger, is also available for use with either metal to metal clamps or back-up flanges. Sizes of 3" and 4" long radius 45 elbows require long tangent to be flanged.

**Belled Ends:** All sizes 2" through 36" (maximum .188 wall thickness) can be belled.

**Rolled Grooved End:** Standard roll grooving capabilities are suitable for use with Victaulic and other fittings.

**Beveled Ends:**

- This product is approved for water distribution piping provided the welding procedures found in attachment B & C are followed.
- This product can be used in the following locations:
  - ....Sanitary DWV drain piping.
  - ....Sanitary building sewer.
  - ....Storm drain piping.
  - ....Storm sewer.
- DWV fittings shall conform to the radius requirements in Comm 82.30 (8).

FELKER BROS. CORP.

Page 2

December 29, 2011

- Additional information is included as attachment(s) to this letter; see attachment A, B and C.

This approval supersedes the approval issued on August 26, 2011 under product file number 20110250.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20110250.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: [jerry.thompson@wi.gov](mailto:jerry.thompson@wi.gov)